

Valve Inspection and Testing

API STANDARD 598
EIGHTH EDITION, MAY 2004



**Helping You
Get The Job
Done Right.SM**

.....

Valve Inspection and Testing

Downstream Segment

API STANDARD 598
EIGHTH EDITION, MAY 2004



**Helping You
Get The Job
Done Right.SM**

SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Standards department telephone (202) 682-8000. A catalog of API publications, programs and services is published annually and updated biannually by API, and available through Global Engineering Documents, 15 Inverness Way East, M/S C303B, Englewood, CO 80112-5776.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the Director of the Standards department, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should be addressed to the Director, Business Services.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.

Copyright © 2004 American Petroleum Institute

FOREWORD

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to API, Standards department, 1220 L Street, NW, Washington, DC 20005.

CONTENTS

	Page
1 GENERAL	1
1.1 Scope	1
1.2 Referenced Publications	1
2 INSPECTION, EXAMINATION, AND SUPPLEMENTARY EXAMINATION	1
2.1 Inspection at the Valve Manufacturer's Plant	1
2.2 Inspection Outside the Valve Manufacturer's Plant	1
2.3 Inspection Notice	1
2.4 Extent of Inspection	2
2.5 Examination	2
2.6 Supplementary Examination	2
3 PRESSURE TESTS	2
3.1 Test Location	2
3.2 Test Equipment	2
3.3 Tests Required	2
3.4 High-pressure Closure Test	3
3.5 High-pressure Pneumatic Shell Test	3
3.6 Test Fluid	3
3.7 Test Pressures	3
3.8 Test Duration	3
3.9 Test Leakage	3
4 PRESSURE TEST PROCEDURES	6
4.1 General	6
4.2 Backseat Test	6
4.3 Shell Test	6
4.4 Low-pressure Closure Test	6
4.5 High-pressure Closure Test	7
5 VALVE CERTIFICATION AND RETESTING	7
5.1 Certificate of Compliance	7
5.2 Re-testing	7

Tables

1-A Pressure Tests	2
1-B Pressure Tests	3
2 Shell Test Pressure	4
3 Other Test Pressures	4
4 Duration of Required Test Pressure	5
5 Maximum Allowable Leakage Rates for Closure Tests	5

NOTES TO PURCHASER

1. If required, the following will be specified in the purchase order:
 - a. Inspections by the purchaser at the valve manufacturer's plant (see 2.1).
 - b. Inspections by the purchaser outside the valve manufacturer's plant (see 2.2).
 - c. Address for inspection notices (see 2.3).
 - d. Any supplementary examination required (see 2.6).
 - e. Type of backseat test (see 3.2.2).
 - f. Low-pressure closure test (see 3.3.3, 3.3.4 and 4.4.2).
 - g. High-pressure closure test (see 3.4 and 4.5).
 - h. High-pressure pneumatic shell test (see 3.5).
 - i. Test fluid temperature for low temperature valves (see 3.6.1).
 - j. Use of a wetting agent in the test water (see 3.6.4).
 - k. Certificate of compliance (see 5.1).
2. If this standard is used for valves not covered by this standard, the purchaser will specify the extent to which the standard is to be applied.

Valve Inspection and Testing

1 General

1.1 SCOPE

1.1.1 This standard covers inspection, examination, supplementary examinations, and pressure test requirements for resilient-seated, nonmetallic-seated (e.g., ceramic), and metal-to-metal-seated valves of the gate, globe, plug, ball, check, and butterfly types. Resilient seats are considered to be:

- a. Soft seats, both solid and semi-solid grease type (e.g., lubricated plug).
- b. Combination soft and metal seats.
- c. Any other type valve designed to meet resilient seat leakage rates as specified in Table 5.

API Std 598 supplements the API standards that reference it, but it may also be applied to other types of valves by agreement between the purchaser and the valve manufacturer.

1.1.2 The inspection requirements pertain to examinations and testing by the manufacturer and any supplementary examinations that the purchaser may require at the valve manufacturer's plant. The test requirements cover both required and optional pressure tests at the valve manufacturer's plant.

1.1.3 The following tests and examinations are specified in this standard:

- a. Shell test.
- b. Backseat test.
- c. Low-pressure closure test.
- d. High-pressure closure test.
- e. Visual examination of castings.
- f. High-pressure pneumatic shell test.

1.2 REFERENCED PUBLICATIONS

1.2.1 The most recent editions of the following standards, codes, and specifications are cited in this standard:

ASME¹

B16.11 *Forged Steel Fittings, Socket-Welding and Threaded*

B16.34 *Valves—Flanged, Threaded, and Welding End*

MSS²

SP-45 *Bypass and Drain Connections*

¹ASME International, 3 Park Avenue, New York, New York 10016. www.asme.org

²Manufacturers Standardization Society of the Valve and Fittings Industry, Inc., 127 Park Street, N.E., Vienna, Virginia 22180. www.mss-hq.com

SP-55 *Quality Standard for Steel Castings for Valves, Flanges and Fittings and Other Piping Components—Visual Method*

SP-91 *Guidelines for Manual Operation of Valves*

1.2.2 This standard supplements the following API valve standards:

API

Std 594 *Check Valves: Wafer, Wafer Lug and Double Flanged Type*

Std 599 *Metal Plug Valves—Flanged, Threaded and Welding End*

Std 602 *Compact Steel Gate Valves—Flanged, Threaded, Welding and Extended Body Ends*

Std 603 *Corrosion-Resistant, Bolted Bonnet Gate Valves—Flanged and Butt-Welding Ends*

Std 608 *Metal Ball Valves—Flanged, Threaded, and Butt-Welding Ends*

Std 609 *Butterfly Valves: Double Flanged, Lug- and Wafer-Type*

2 Inspection, Examination, and Supplementary Examination

2.1 INSPECTION AT THE VALVE MANUFACTURER'S PLANT

The purchaser will specify in the purchase order his intention to inspect valves and witness tests and examinations at the valve manufacturer's plant. The purchaser's inspector shall have free access to any part of the plant concerned with manufacture of the valves whenever work on the order is under way.

2.2 INSPECTION OUTSIDE THE VALVE MANUFACTURER'S PLANT

When the purchaser specifies that the inspection will include shell components manufactured at locations other than the valve manufacturer's plant, these components shall be subject to the purchaser's inspection at the location where they are manufactured.

2.3 INSPECTION NOTICE

When inspection by the purchaser is specified, the valve manufacturer shall notify the purchaser 5 working days prior to the required valve testing and any specified supplementary inspections or examinations, addressing the notice as stated in the purchase order. The valve manufacturer shall also give the purchaser 5 working days' notice of where and when shell components manufactured outside the valve manufacturer's plant may be inspected, if such inspection is required.

Table 1-A—Pressure Tests

Valves: NPS ≤ 4 & ASME Class ≤ 1500
NPS > 4 & ASME Class ≤ 600

Test Description	Valve Type					
	Gate	Globe	Plug	Check	Floating Ball	Butterfly and Trunnion Mounted Ball
Shell	Required	Required	Required	Required	Required	Required
Backseat ^a	Required	Required	NA	NA	NA	NA
Low-pressure Closure	Required	Optional ^c	Required ^b	Optional ^c	Required	Required
High-pressure Closure ^d	Optional ^{c, f}	Required ^e	Optional ^{b, c, f}	Required	Optional ^{c, f}	Optional ^{c, f}

Notes: NA = Not applicable.

^aThe backseat test is required for all valves, except for bellows seal valves, that have the backseat feature.

^bFor lubricated plug valves, the high-pressure closure test is mandatory and the low-pressure closure test is optional.

^cWhen the purchaser specifies an “optional” test, the test shall be performed in addition to the required tests.

^dThe high-pressure closure test of resilient-seated valves may degrade subsequent sealing performance in low-pressure service.

^eFor power-operated and manually operated gear actuated globe valves, including non-return type globe valves, the high-pressure closure test shall be performed at 110% of the design differential pressure used for sizing of the operator.

^fA high-pressure closure test is required for all valves specified to be double block and bleed valves.

2.4 EXTENT OF INSPECTION

The extent of inspection may be specified in the purchase order and, unless otherwise indicated, will be limited to the following:

- Inspection of the valve during assembly to ensure compliance with the specifications of the purchase order. Inspection may include the use of specified nondestructive methods.
- Witnessing of the required and specified optional pressure tests and examinations.
- Witnessing of any supplementary examinations (see 2.6).
- Review of mill records and nondestructive examination records (including specified radiographs).

2.5 EXAMINATION

2.5.1 A visual examination shall be performed by the valve manufacturer of all castings of bodies, bonnets, covers, and closure elements to assure conformance with MSS SP-55.

2.5.2 The valve manufacturer shall examine each valve to assure compliance with this standard and the referenced purchase specification (e.g., API Std 599).

2.5.3 All examinations shall be performed in accordance with written procedures that comply with the applicable standards.

2.6 SUPPLEMENTARY EXAMINATION

Supplementary types of examination are required only if specified in the purchase order and only to the extent specified. Magnetic particle, radiographic, liquid penetrant, and ultrasonic examination of steel castings or forgings shall be in accordance with Part 8 of ASME B16.34 or with the purchaser’s own procedures and acceptance criteria, if so speci-

fied. These examinations shall be made by the valve manufacturer subject to witnessing by the purchaser’s inspector.

3 Pressure Tests

3.1 TEST LOCATION

Pressure tests shall be performed by the valve manufacturer at the valve manufacturer’s plant.

3.2 TEST EQUIPMENT

The equipment used by the valve manufacturer to perform the required pressure tests shall not apply external forces that affect seat leakage. If an end-clamping fixture is used, the valve manufacturer shall be able to demonstrate that the test fixture does not affect the seat sealing capability of the valve being tested. End clamping is allowed for valves designed to function between mating flanges, such as wafer check and wafer butterfly valves.

3.3 TESTS REQUIRED

3.3.1 The pressure tests listed in Table 1-A or 1-B shall be performed on each valve in accordance with written procedures that comply with this standard.

3.3.2 At the manufacturer’s option, the backseat test for valves that have the backseat feature may be either a high-pressure or a low-pressure test unless stated otherwise in the purchase order.

3.3.3 Valves NPS 4 and smaller having pressure ratings up to and including ASME Class 1500 and valves larger than NPS 4 having pressure ratings up to and including ASME Class 600 shall be tested in accordance with Table 1-A.

Table 1-B—Pressure Tests

Valves: NPS ≤ 4 & ASME Class > 1500
NPS > 4 & ASME Class > 600

Test Description	Valve Type					
	Gate	Globe	Plug	Check	Floating Ball	Butterfly and Trunnion Mounted Ball
Shell	Required	Required	Required	Required	Required	Required
Backseat ^a	Required	Required	NA	NA	NA	NA
Low-pressure Closure	Optional ^b	Optional ^b	Optional ^b	Optional ^b	Required	Optional ^b
High-pressure Closure ^c	Required	Required ^d	Required	Required	Optional ^{b, e}	Required

Notes: NA = Not applicable.

^aThe backseat test is required for all valves, except for bellows seal valves, that have the backseat feature.

^bWhen an “optional” test is specified by the purchaser, the test shall be performed in addition to the required tests.

^cThe high-pressure closure test of resilient-seated valves may degrade subsequent sealing performance in low-pressure service.

^dFor power-operated and manually operated gear actuated globe valves, including non-return type globe valves, the high-pressure closure test shall be performed at 110% of the design differential pressure used for sizing of the operator.

^eA high-pressure closure test is required for all valves specified to be double block and bleed valves.

The purchaser may elect to require an “optional” pressure test in Table 1-A.

3.3.4 Valves NPS 4 and smaller having pressure ratings greater than ASME Class 1500 and valves larger than NPS 4 having pressure ratings greater than ASME Class 600 shall be tested in accordance with Table 1-B.

The purchaser may elect to require an “optional” pressure test in Table 1-B.

3.4 HIGH-PRESSURE CLOSURE TEST

The high-pressure closure test is required for several valve types, as shown in Table 1-A and 1-B. For the valve types for which, according to Table 1-A and 1-B, the high-pressure closure test is optional, the valves are still required to be able to pass the test (as a test of the design of the valve closure structure). Results of tests confirming the capacity of the valve design to pass the high-pressure closure test shall be supplied when requested in the inquiry purchase requisition, or by the purchaser.

3.5 HIGH-PRESSURE PNEUMATIC SHELL TEST

When specified by the purchase order, a high-pressure pneumatic shell test shall be performed. This test shall be performed after the hydrostatic shell test, using appropriate safety precautions. The pneumatic shell test pressure shall be 110% of the maximum allowable pressure at 100°F (38°C) or as specified in the purchase order. Visible leakage is not allowed.

3.6 TEST FLUID

3.6.1 For shell, high-pressure backseat, and high-pressure closure tests, the test fluid shall be air, inert gas, kerosene, water, or a non-corrosive liquid with a viscosity not higher

than that of water. Unless otherwise specified in the purchase requisition, the test fluid temperature shall be within the range 41°F (5°C) to 122°F (50°C).

3.6.2 For the low-pressure closure and low-pressure backseat tests, the test fluid shall be air or inert gas.

3.6.3 When air or gas is used for closure, shell, or backseat tests, the valve manufacturer shall be capable of demonstrating the adequacy of the method of leakage detection.

3.6.4 Water used for any test may contain water-soluble oil or rust inhibitor. When specified by the purchaser, a wetting agent shall be included in the water. For testing of austenitic stainless steel valves, water with chloride content not exceeding 100 parts per million shall be used. The valve manufacturer shall be able to document the chloride content.

3.7 TEST PRESSURES

3.7.1 The shell test pressure shall be as listed in Table 2.

3.7.2 Other test pressures shall be as listed in Table 3.

3.8 TEST DURATION

For each type of test, the required test pressure shall be maintained for at least the minimum time specified in Table 4.

3.9 TEST LEAKAGE

3.9.1 Shell, Stem Seals, and Backseat

3.9.1.1 For shell tests, visually detectable leakage through the pressure boundary walls and any fixed body joint is not permitted.

3.9.1.2 For backseat tests, visually detectable leakage is not permitted.

Table 2—Shell Test Pressure

Valve Type	Class	Shell Test Pressure (Minimum)	
		Pounds per Square Inch Gauge	Bar
Ductile Iron	150	400	26
	300	975	66
Cast Iron	125		
NPS 2-12		350	25
NPS 14-48		265	19
Cast Iron	250		
NPS 2-12		875	61
NPS 12-24		525	37
Steel			
Flanged	150 – 2500	b	
Buttweld	150 – 4500	b	
Threaded ^a and Socketweld	800	c	
	150 – 4500	b	

Notes:

^a ASME B16.34 limits threaded-end valves to Class 2500 and lower.

^b Per ASME B16.34.

^c For Class 800 valves, the shell test pressure shall be 1¹/₂ times the pressure rating at 100°F (38°C), rounded off to the next higher increment of 25 pounds per square in. gauge (or 1 bar) (see Table 2 of API Std 602).

Table 3—Other Test Pressures

Test	Test Pressure ^d	
	Pounds per Square Inch Gauge	Bar
Valves Except Butterfly and Check		
High-pressure closure and backseat ^a	b	
Low-pressure closure and backseat ^a	60 – 100	4 – 7
Butterfly Valve		
High-pressure closure	c	
Low-pressure closure	60 – 100	4 – 7
Check Valve		
High-pressure closure		
Class 125 (cast iron)		
NPS 2-12	200	14
NPS 14-48	150	11
Class 250 (cast iron)		
NPS 2-12	500	35
NPS 14-24	300	21
Class 150 (ductile iron)	250	17
Class 300 (ductile iron)	640	44
Carbon, alloy, stainless steel, and special alloys	b	
Low-pressure closure (See Tables 1-A and 1-B)	60 – 100	4 – 7

Notes:

^aThe backseat test is required for all valves that have this feature.

^b110% of maximum allowable pressure at 100°F (38°C) in accordance with the applicable purchase specification.

^c110% of design differential pressure at 100°F (38°C) in accordance with the applicable purchase specification.

^dSingle values shown are minimum test pressures. A range of values indicates both minimum and maximum test pressures.

Table 4—Duration of Required Test Pressure

Valve Size (NPS)	Minimum Test Duration (Seconds) ^a				
	Shell		Backseat	Closure	
	Check Valves (API Std 594)	Other Valves	All Valves with Backseat Feature	Check Valves (API Std 594)	Other Valves
≤ 2	60	15	15	60	15
2 ¹ / ₂ – 6	60	60	60	60	60
8 – 12	60	120	60	60	120
≥ 14	120	300	60	120	120

Note: ^aThe test duration is the period of inspection after the valve is fully prepared and is under full pressure.

Table 5—Maximum Allowable Leakage Rates for Closure Tests

Valve Size (NPS)	All Resilient Seated Valves ^b	All Metal-seated Valves Except Check		Metal-seated Check Valves	
		Liquid Test ^a (Drops Per Minute)	Gas Test (Bubbles Per Minute)	Liquid Test	Gas Test
≤ 2	0	0 ^b	0 ^b	c	d
2 ¹ / ₂ – 6	0	12	24	c	d
8 – 12	0	20	40	c	d
≥ 14	0	e	f	c	d

Notes:

^aFor the liquid test, 1 milliliter is considered equivalent to 16 drops.

^bThere shall be no leakage for the minimum specified test duration (see Table 4). For liquid test, 0 drops means no visible leakage per minimum specified test duration. For gas test, 0 bubbles means less than 1 bubble per minimum specified test duration.

^cThe maximum permissible leakage rate shall be 0.18 cubic in. (3 cubic centimeters) per minute per in. of nominal pipe size.

^dThe maximum permissible leakage rate shall be 1.5 standard cubic ft (0.042 cubic meter) of gas per hour per in. of nominal pipe size.

^eFor valves greater than or equal to NPS 14, the maximum permissible leakage rate shall be 2 drops per minute per in. NPS.

^fFor valves greater than or equal to NPS 14, the maximum permissible leakage rate shall be 4 bubbles per minute per in. NPS.

3.9.1.3 For valves with adjustable stem seals, leakage through the stem seals during the shell test shall not be cause for rejection. However, the manufacturer shall demonstrate that the stem seals are capable of retaining pressure at least equal to the 100°F (38°C) valve rating without visible leakage.

3.9.1.4 For valves with non-adjustable stem seals (o-rings, fixed single rings, and the like), visually detectable leakage during the shell test is not permitted.

3.9.1.5 Where no visual detectable leakage is permitted, the following definitions apply:

- If the test fluid is a liquid, there shall be no visible evidence of drops or wetting of the external surfaces of the test valve.
- If the test fluid is air or inert gas, no leakage will be revealed by the established detection method.

3.9.2 For both the low-pressure closure test and the high-pressure closure test, visual evidence of leakage through the disk, behind the seat rings, or past the shaft seals (of valves that have this feature) is not permitted and structural damage is not permitted. (Plastic [permanent] deformation of resilient seats and seals is not considered structural damage.) The allowable rate for leakage of test fluid at the seat-sealing surface interface, for the duration of the tests, is listed in Table 5.

3.9.3 The allowable leakage rate for closure tests of valves with nonmetallic (e.g., ceramic) seat materials shall be equal to that specified in Table 5 for a metal-seated valve of equivalent size and type.

4 Pressure Test Procedures

4.1 GENERAL

4.1.1 Valves designed to permit emergency or supplemental introduction of an injectable sealant to the seat area shall be tested with the injection system empty and not in use, except for lubricated plug valves.

4.1.2 When a liquid is used as the test fluid, the valve shall be essentially free from trapped air during the test.

4.1.3 Required protective coatings, such as paint, which may mask surface defects, shall not be applied to any surface before inspection or pressure testing. (Phosphatizing and similar chemical conversion processes used to protect valve surfaces are acceptable even if applied before the tests, provided that they will not seal off porosity.)

4.1.4 When closure testing valves, the valve manufacturer's test procedure shall ensure that excessive force is not used to close the valve. The applied force may be determined from the appropriate figures in MSS SP-91, but in any case shall not exceed the values published by the valve manufacturer.

4.1.5 The valve shall be visually examined for leakage after it has been fully prepared and is under full test pressure.

4.2 BACKSEAT TEST

4.2.1 The backseat test is required for all valves, except for bellows seal valves, that have the backseat feature and shall be performed by applying pressure inside the assembled valve with the valve ends closed, the valve fully open, and the packing gland loose or packing not installed. If the backseat test is performed after the shell test, the packing shall be installed and/or packing glands re-tightened after the backseat test. The successful completion of the backseat test shall not be construed as a recommendation by the valve manufacturer that, while the valve is pressurized, the valve stuffing box may be repacked or the packing may be replaced.

4.2.2 For valves 4 in. NPS and smaller, the backseat test may be combined with the shell test when volumetric devices are used to monitor leakage from the shell and backseat. When tested by this method, the packing shall be loose. The manufacturer shall be responsible for demonstrating that the packing will not leak at the valve's rated pressure at 100°F (38°C).

4.3 SHELL TEST

Except as provided in 4.2.2, the shell test shall be made by applying the pressure inside the assembled valve with the valve ends closed, the valve partially open, and any packing gland tight enough to maintain the test pressure, thereby, except for bellows seal valves, testing the stuffing box.

4.4 LOW-PRESSURE CLOSURE TEST

4.4.1 The low-pressure closure test shall be performed with the seat sealing surface interface clean and free from oil, grease, and sealant. If necessary to prevent galling, the sealing surfaces may be coated with a film of oil that is not heavier than kerosene. This requirement does not apply to a valve that uses a lubricant as its primary seal (e.g., lubricated plug valves).

4.4.2 Any leakage at the seat sealing surface interface, behind the seat ring, or through the disk on the open side of the valve shall be detected when bubbles are observed coming from the closure (disk, seat, and seat ring), which is either covered with water or coated with a soap or similar solution.

As an alternative, displacement measuring devices may be used, provided that the detectable leakage rate is equivalent to that given in Table 5, the valve manufacturer can demonstrate and validate that the procedure yields results equivalent to the requirements of this standard, and the device has been accepted by agreement between the purchaser and the manufacturer. Bubbler testing, when used for valves larger than NPS 2, shall only be acceptable when agreed to by the purchaser.

When volumetric devices (bubblers) are used to measure leakage, the test duration shall not begin until flow through the test tubing is established and stabilized. The device shall be calibrated to yield results equivalent to the units per minute listed in Table 5. Volumetric devices shall be calibrated with the same test fluid and at the same temperature as used for the production tests.

4.4.3 When closure testing gate, plug, and ball valves, the valve manufacturer shall use a method of testing seat leakage that fills and fully pressurizes the body cavity to the test pressure between the seats and the bonnet area, as applicable, with the test fluid. This will ensure that no seat leakage can escape detection because of gradual filling of these volumes during the test period.

For a valve (other than a double block-and-bleed valve or globe valve) designed to close against pressure from either direction, the pressure shall be applied successively to each side of the closed valve with the other side open to the atmosphere to check for leakage at the atmospheric side of the closure. For a globe valve, pressure shall be applied in one direction with the pressure applied under the disk.

For a valve designed to close against pressure from one direction only and so marked, the pressure shall be applied on the pressure side of the valve only. For a check valve, the pressure shall be applied on the downstream side.

For a double block-and-bleed valve, the pressure shall be applied successively to each side of the closure through the valve port. Leakage into the body cavity between the seats shall be checked through observation at a tapped opening between the seats. Valves shall be tested with the stem in the

vertical upright position. Leakage from the seats shall not exceed rates shown in Table 5.

A closure test is required only in one direction for butterfly valves furnished with encapsulation or resilient internal liners and designed for use with Class 125 or Class 150 flanges (API Std 609 Category A valves). For other resilient-seated butterfly valves (API Std 609 Category B valves), the closure test is required in both directions. For valves with a preferred flow direction, the closure test in the non-preferred direction shall be based on the reduced differential pressure rating in that direction.

4.4.4 Trapping test air or gas in the body cavity between the seats of a one-piece (solid or flexible) wedge gate valve and subsequently covering the seats with water or coating them with soap or a similar solution does not constitute an acceptable low-pressure closure test.

4.4.5 If a tapped connection in the body cavity is made to permit testing procedures described under double block-and-bleed valve in 4.4.3, the connection shall be in accordance with MSS SP-45 and shall be fitted before shipment with a solid pipe plug (in accordance with ANSI B16.11) whose material composition is equivalent to that of the valve shell.

4.5 HIGH-PRESSURE CLOSURE TEST

4.5.1 The procedure for the high-pressure closure test shall be the same as the procedure for the low-pressure closure test except that, in the case of a liquid test, leakage shall be detected when drops, not bubbles as described in 4.4 are observed.

5 Valve Certification and Retesting

5.1 CERTIFICATE OF COMPLIANCE

When specified by the purchaser, the valve manufacturer shall submit to the purchaser a certificate of compliance as required in the purchase order.

5.2 RE-TESTING

A completed valve does not require re-testing unless inspection by the purchaser is specified in the purchase order. This re-testing may be waived by the purchaser's inspector upon written certification by the manufacturer that the valve has been inspected, tested, and examined for conformance with the requirements of this standard. Painted valves need not have paint removed for re-testing. Stored valves shall be commercially cleaned before re-testing and before shipment.



**American Petroleum Institute
2004 Publications Order Form**

Effective January 1, 2004.

API Members receive a 50% discount where applicable.

The member discount does not apply to purchases made for the purpose of resale or for incorporation into commercial products, training courses, workshops, or other commercial enterprises.

Available through Global Engineering Documents:

Phone Orders: 1-800-854-7179 (Toll-free in the U.S. and Canada)
303-397-7956 (Local and International)

Fax Orders: 303-397-2740

Online Orders: www.global.ihs.com

Date: _____

API Member (Check if Yes)

Invoice To (Check here if same as "Ship To")

Name: _____
 Title: _____
 Company: _____
 Department: _____
 Address: _____

 City: _____ State/Province: _____
 Zip/Postal Code: _____ Country: _____
 Telephone: _____
 Fax: _____
 E-Mail: _____

Ship To (UPS will not deliver to a P.O. Box)

Name: _____
 Title: _____
 Company: _____
 Department: _____
 Address: _____

 City: _____ State/Province: _____
 Zip/Postal Code: _____ Country: _____
 Telephone: _____
 Fax: _____
 E-Mail: _____

Quantity	Product Number	Title	SO★	Unit Price	Total

Payment Enclosed **P.O. No.** (Enclose Copy) _____

Charge My Global Account No. _____

VISA **MasterCard** **American Express** **Diners Club** **Discover**

Credit Card No.: _____

Print Name (As It Appears on Card): _____

Expiration Date: _____

Signature: _____

Subtotal	
Applicable Sales Tax (see below)	
Rush Shipping Fee (see below)	
Shipping and Handling (see below)	
Total (in U.S. Dollars)	

★ To be placed on **Standing Order** for future editions of this publication, place a check mark in the SO column and sign here:

Pricing and availability subject to change without notice.

Mail Orders – Payment by check or money order in U.S. dollars is required except for established accounts. State and local taxes, \$10 processing fee*, and 5% shipping must be added. Send mail orders to: **API Publications, Global Engineering Documents, 15 Inverness Way East, M/S C303B, Englewood, CO 80112-5776, USA.**

Purchase Orders – Purchase orders are accepted from established accounts. Invoice will include actual freight cost, a \$10 processing fee*, plus state and local taxes.

Telephone Orders – If ordering by telephone, a \$10 processing fee* and actual freight costs will be added to the order.

Sales Tax – All U.S. purchases must include applicable state and local sales tax. Customers claiming tax-exempt status must provide Global with a copy of their exemption certificate.

Shipping (U.S. Orders) – Orders shipped within the U.S. are sent via traceable means. Most orders are shipped the same day. Subscription updates are sent by First-Class Mail. Other options, including next-day service, air service, and fax transmission are available at additional cost. Call 1-800-854-7179 for more information.

Shipping (International Orders) – Standard international shipping is by air express courier service. Subscription updates are sent by World Mail. Normal delivery is 3-4 days from shipping date.

Rush Shipping Fee – Next Day Delivery orders charge is \$20 in addition to the carrier charges. Next Day Delivery orders must be placed by 2:00 p.m. MST to ensure overnight delivery.

Returns – All returns must be pre-approved by calling Global's Customer Service Department at 1-800-624-3974 for information and assistance. There may be a 15% restocking fee. Special order items, electronic documents, and age-dated materials are non-returnable.


***Minimum Order** – There is a \$50 minimum for all orders containing hardcopy documents. The \$50 minimum applies to the order subtotal including the \$10 processing fee, excluding any applicable taxes and freight charges. If the total cost of the documents on the order plus the \$10 processing fee is less than \$50, the processing fee will be increased to bring the order amount up to the \$50 minimum. This processing fee will be applied before any applicable deposit account, quantity or member discounts have been applied. There is no minimum for orders containing only electronically delivered documents.

There's more where this came from.

The American Petroleum Institute provides additional resources and programs to the oil and natural gas industry which are based on API® Standards. For more information, contact:

- | | |
|---|--|
| • API Monogram® Licensing Program | Phone: 202-962-4791
Fax: 202-682-8070 |
| • American Petroleum Institute Quality Registrar (APIQR®) | Phone: 202-962-4791
Fax: 202-682-8070 |
| • API Spec Q1® Registration | Phone: 202-962-4791
Fax: 202-682-8070 |
| • API Perforator Design Registration | Phone: 202-962-4791
Fax: 202-682-8070 |
| • API Training Provider Certification Program | Phone: 202-682-8490
Fax: 202-682-8070 |
| • Individual Certification Programs | Phone: 202-682-8064
Fax: 202-682-8348 |
| • Engine Oil Licensing and Certification System (EOLCS) | Phone: 202-682-8516
Fax: 202-962-4739 |
| • API PetroTEAM™ (Training, Education and Meetings) | Phone: 202-682-8195
Fax: 202-682-8222 |

Check out the API Publications, Programs, and Services Catalog online at www.api.org.



Helping You Get The Job Done Right.®

Additional copies are available through Global Engineering Documents at (800) 854-7179 or (303) 397-7956

Information about API Publications, Programs and Services is available on the World Wide Web at: <http://www.api.org>



**American
Petroleum
Institute**

1220 L Street, Northwest
Washington, D.C. 20005-4070
202-682-8000

Product No. C59808